

TOWN OF HARWICH



BOARD OF HEALTH
732 Main Street Harwich, MA 02645
508-430-7509 – Fax 508-430-7531
E-mail: health@town.harwich.ma.us

Town of Harwich Board of Health
Tuesday, September 8, 2015-6:30 PM (Please Note Summer Schedule)
TOWN HALL – SMALL HEARING ROOM

AGENDA

I CALL TO ORDER

II MINUTES OF PREVIOUS MEETING – 8/11/2015

Minutes shall be reviewed; proposed changes shall be possible; and a vote to approve with any noted changes shall be taken.

III 6:30 – 7:00 PM - BOARD OF HEALTH WORK SESSION

A. Accela Permit Dept. Computer Program Presentation by Dept. Staff
Vote to accept/deny/take under advisement

IV 7:00 PM - OLD/UNFINISHED BUSINESS

Vote to accept/deny/take under consideration

V NEW BUSINESS

A. **Hearing-Vangel, 1 Village Green, Harwich Port**, to consider variances to install a new Title 5 septic system prepared by Moran Engineering Associates, LLC.

Variances from 310 CMR 15.211(1) Minimum Setback Distances:

1. Per 310 CMR 15.405(1)(a): to allow a septic tank to be 5' from a lot line where 10' is required. Variance request of 5'.

2. Per 310 CMR 15.405(1)(a): to allow a septic tank to be 7.5' from a lot line where 10' is required. Variance request of 2.5'.

3. Per 310 CMR 15.405(1)(a): to allow the soil absorption system to be 5.2' from a lot line where 10' is required. Variance request of 4.8'.

4. Per 310 CMR 15.405(1)(a): to allow the soil absorption system to be 5' from a lot line where 10' is required. Variance request of 5'.

5. Per 310 CMR 15.405(1)(b): to allow for the septic tank to be 6.7' from the crawl space where 10' is required. Variance request of 3.3'.

6. Per 310 CMR 15.405(1)(b): to allow for the soil absorption system to be 5.2' from the crawl space where 20' is required. Variance request of 14.8'

Vote to accept/deny/take under consideration

VI REPORT OF THE HEALTH DIRECTOR

- August Monthly Report
- Complaints
- Food Service
- Flu Clinics
- Special Projects

VII **CORRESPONDENCE**

Vote to accept/deny/take this under consideration

VIII **PERMITS**

PERMITS TO BE ISSUED				
Business Name	Business Location	Type	Sub-Type	CurrentNo
Bosetti Septic Systems	199 Church Street, East Harwich	installer	septic installer	15-58
Ernie Joy Excavating & Septic	52 Lovers Lane, Harwich	installer	septic installer	15-59
Holmes Land Service	18 Sadie's Way Harwich	installer	septic installer	15-61
Trolley Dogs/Boston Italian Ice	26 Claudette Circle, Framingham, MA	food service	temporary food service	15-176
Olde C Dogs	485 Center Street, Dennisport, MA	food service	temporary food service	15-177
Lewis Brothers Homemade Ice Cream	310 Commercial Street, Provincetown, MA	food service	temporary food service	15-175
Harvest Homes Inc.	600 Worcester Road, Framingham, MA	installer	septic installer	15-60

Vote to accept/deny/take this under consideration

IX **OTHER**

Vote to accept/deny/take this under consideration

X **ADJOURN**

BOH Agenda 9/8/2015

Authorized posting officer:

Posted by:

Jennifer Clarke

Signature

Date

Town Clerk

Date

Per the Attorney General’s Office: The committee may hold an open session for topics not reasonably anticipated by the Chair 48 hours in advance of the meeting following “New Business.” If you are deaf or hard of hearing or a person with a disability who requires an accommodation, contact the Selectmen’s Office at

508-430-7513